

Additional Comments:

**** Portion Below This Line To Be Filled Out by MoDOT ****

Comments:

This concept proposal provides for a substitution of a 6IN. covered aluminum cable tray in lieu of PVC Coated Aluminum Conduit. Based on discussions with District MoDOT Lighting, approval is recommended for this concept proposal. Cost savings are currently under review.

Submitted By Resident Engineer

Date

Comments:

**Approval
Recommended**

District Engineer

Date

**Rejection
Recommended**

Comments:

**Approval
Recommended**

Federal Highway Administration
Required for FHWA Full Oversight Projects

Date

**Rejection
Recommended**

Comments:

Approval

State Construction and Materials Engineer

Date

Rejection