

Missouri Department of Transportation  
Roberta Broeker, Interim Director

573.751.2551  
Fax: 573.751.6555  
1.888.ASK MODOT (275.6636)

## ADDENDUM 003 Request for Bid King City Maintenance Building RFB 9-150708KH

Bidders should acknowledge receipt of Addendum 003 (THREE) by signing and including it with the original bid. The due date for receipt of bids **has not** changed by this Addendum; the due date is **July 8, 2015 2:00 PM Central Time**. Accordingly, the following clarifications, and or additional information, are believed to be of general interest to all potential bidders. All other terms and conditions remain unchanged and in full force.

Name and Title of Signer (Print or type)	Name and Title of Department Authority  Kristi Hixson General Services Senior Specialist
Contractor/Offeror Signature   (Signature of person authorized to sign)	Department of Transportation  <i>Kristi Hixson</i>  (Authorizing Signature)
Date Signed:	Date Signed:7/2/2015

### Pre-Bid Clarification

Trusses are on 4-foot centers as on plan sheets.

**Question:** Where is the benchmark for building elevation?

**Answer:** The benchmark is on the power pole on the west side of US Route 169 on the NW corner of MoDOT property.

